

Software Name: MX-AOPC UA Server

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
V2.0	Build18031616	No change	ioLogik 2500 series ioLogik E1200 series ioLogik E1500 series ioLogik E2200 series ioLogik E4200 ioLogik W5300 series ioPAC 8500 Series ioPAC 8600 Series MX-AOPC UA Suite <ul style="list-style-type: none"> ● MX-AOPC UA Server V2.x ● MX-AOPC UA Logger V2.x 	New Features: <ol style="list-style-type: none"> 1. Support configuration file encryption 2. Support Modbus polling continuous address 3. Support Modbus Delay between Polling setting 4. Support import or export multiple Modbus devices 	Bugs Fixed: <ol style="list-style-type: none"> 1. Fixed Nodeld is not persistent. 	Note: The configuration file will be encrypted when upgrading from V1.x to V2.x, which cannot be downgraded from V2.x to V1.x anymore.
V1.6	Build17051914	No change	No change	New Features: <ol style="list-style-type: none"> 1. Link to .NET Framework's download URL 2. Added license.moxa.com in the expiration warning message 3. Added Device Timestamp (UTC+T.Z.) column in Viewer 	Bugs Fixed: <ol style="list-style-type: none"> 1. Fixed unable to recognize network adapters setting as teaming mode. 2. Fixed unable to trigger "Update Configuration to Server" button after modifying Modbus/TCP Tag property. 	N/A
V1.5	Build16082218	No change	No change	N/A	Bugs Fixed: <ol style="list-style-type: none"> 1. Fixed all tags of ioLogik E1200 series are updated at the same time when on change mode of all tags is enabled. 2. Fixed wrong time zone issue when the tags of ioLogik E1200 series are created on the server at the first time. 	N/A

Software Name: MX-AOPC UA Server

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
V1.4	Build16072116	No change	No change	New Features: 1. Support MX-AOPC UA Logger 2. Removed supporting anonymous type connection with OPC UA client for security improvement.	Bugs Fixed: 1. Fixed signed integer data type tag became unknown data type after executing refresh function on Viewer 2. Fixed string type internal register tag caused Viewer freeze 3. Fixed OPC UA client did not show device disconnection status when device did not connect to MX-AOPC UA Server 4. Fixed monitored items without source timestamp and status code 5. Fixed wrong sampling Interval caused OPC UA client unable to receive tag update notifications 6. Fixed OPC UA client cannot connect to MX-AOPC UA Server unless CA is trusted when security policy was set to NONE 7. Fixed OPC UA client still can read tag value when tag quality is in disconnect status 8. Fixed unable to click "Close" button of Certificate Management dialog on Windows 7 English version and Windows 8 platform 9. Fixed wrong RTD tag value for the ioLogik E4200 and M-6200 10. Fixed wrong time zone offset when Device time zone is set to (GMT+12)Fiji, Kamchatk...	N/A
V1.3	Build15090819	Microsoft Windows 7 Microsoft Windows 8 Microsoft Windows 10 Microsoft Windows Server 2003 Microsoft Windows Server 2008 Microsoft Windows Server 2012	ioLogik 2500 series ioLogik E1200 series ioLogik E1500 series ioLogik E2200 series ioLogik E4200 ioLogik W5300 series MX-AOPC UA Suite ● MX-AOPC UA Server V1.x ● MX-AOPC UA Logger V1.x	New Features: 1. First release for ioLogik 2500-WL1 series 2. Add "De-active License" function	N/A	N/A